

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08275
Name of Facility: Robert Morgan Educational Center
Address: 18180 SW 122 Avenue
City, Zip: Miami 33177

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: MDCPS
Person In Charge: MDCPS Phone: (786) 275-0400
PIC Email: ecaldwell@dadeschools.net

Inspection Information

Purpose: Routine
Inspection Date: 9/25/2024

Begin Time: 12:50 PM
End Time: 02:10 PM

Additional Information

FEMALES 635 CENSUS 1357
MALES 722

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | | | |
|--|----|--------------------------------|----|-----------------------------------|
| SCHOOL SANITATION | IN | 11. Group Toilet Rooms | IN | 21. Pest Control |
| IN 1. School Site | IN | 12. Toilet Facilities | IN | SAFETY |
| IN 2. Playground, Equip & Athletic Fields* | IN | 13. Handwashing Facilities | IN | 22. First Aid Kit |
| IN 3. Athletic & Playground Equipment | IN | 14. Soap Dispensers | IN | DIAPER CHANGING STATION |
| BUILDING CONST/MAINT. | NA | 15. Shower Facilities | NA | 23. Sanitizers |
| IN 4. Construction | NA | 16. Showers Water Temperatures | NA | 24. Changing Station & Mats |
| OUT 5. Maintenance & Repair | | WATER SUPPLY | NA | 25. Hand Sink |
| IN 6. Lighting Standards | IN | 17. Approved Source | NA | 26. Garbage Can |
| IN 7. Heating, Ventilation, A/C Standards | IN | 18. Drinking Fountains | NA | ANIMAL HEALTH & SAFETY |
| IN 8. Natural Ventilation | | LIQUID WASTE & WASTE WATER | NA | 27. Animal Maintenance/Aggressive |
| IN 9. Mechanical Ventilation | IN | 19. Sewage Disposal | NA | DORM/RESIDENTIAL FACILITIES |
| SANITARY FACILITIES | IN | 20. Solid Waste | NA | 28. Maintenance/Complaint |
| IN 10. Provided/Accessible/Separation | | PEST CONTROL | NA | 29. Other |

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Group inspection:
Ericka Caldwell-Clinch (Director).
Ismany Gondar (AP).
Joseph Evans (AP), signed and assisted with the inspection.

Email Address(es): ecaldwell@dadeschools.net;
igondar@dadeschools.net;
josephevans@dadeschools.net;

Violations Comments

Violation #5. Maintenance & Repair

Observations:

Stains on Ceiling Panels:

1. Room # 667 (one (1) stained ceiling panel).
2. Room # 673 (five (5) stained ceiling panels).

Replace all stained ceiling panels.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Alberto Reyes (032763)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Joseph Evans (AP)
Date: 9/25/2024

Inspector Signature:

Handwritten signature of Alberto Reyes.

Client Signature:

Handwritten signature of Joseph Evans.